



NOTE: LADDER MUST NOT IMPEDE OPENING OF WINDOW

20" MINIMUM

12" MINIMUM

24" MINIMUM

36" MINIMUM

36" MINIMUM

LADDER OR STEPS MUST BE INCLUDED ON WINDOW WELLS EXCEEDING 44" VERTICAL DEPTH

MINIMUM 9-SQ.-FT. AREA

44" MAXIMUM